



**ACS.CHANGEOVER
CORE GENERIC.PART B
SAFETY ASSESSMENT CRITERIA
INITIAL & RE-ASSESSMENT
DOMESTIC TO NON-DOMESTIC
NATURAL GAS & LPG**

Introduction

Tests gas safety competence of those intending to extend domestic gas work range to include non-domestic Natural Gas work range.

Comprises

3. Products and characteristics of combustion.

CBs may adopt Competence and Criteria numbering different to that used in this document.

CB documentation may adopt wording for criteria different to that used in this document, provided the meaning is unaffected.

Range

All non-domestic gas fittings.

Pre-requisites**Initial**

c/o ND Core Generic Part A
CCN1 or
CCLP1 or
QCF or S/NVQ.

Re-assessment

c/o ND Core Generic Part A & B
CCN1 or
CCLP1 or
QCF or S/NVQ.

Exclusions

Work previously covered in CCN1 or CCLP1.

References and normative documents

MIs.

All relevant documents as listed in the Legislative, Normative & Informative Document List (LINDL), inc.:

- HSL56
- GIUSP

ACS.SMB. 003.ACDND identifies Normative Documents that should be held by ACs.

Abbreviations

AC. Assessment Centre
CB. Certification body
MIs. Manufacturer's/manufacturers' instructions
Ref. Reference.

3. Products and characteristics of combustion (for natural draught burners)

PERFORMANCE CRITERIA		REF	I	R
1.	inspect flame pictures of selection of natural draft atmospheric burners and identify those indicating:			
(i)	complete combustion		✓	✓
(ii)	incomplete combustion		✓	✓